

*499 Jay Windom Martin Residence Hvac Design
HVAC Load Calculations*

for

499 Jay Windom Martin Residence
6406 Westover Dr. Granbury, TX.



RHVAC RESIDENTIAL
HVAC LOADS

Prepared By:

499 Jay Windom Martin Residence
6406 Westover Dr. Granbury, TX.

Monday, October 13, 2025

Rhvac is an ACCA approved Manual J, D and S computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.



Project Report

General Project Information

Project Filename: C:\Users\User\AppData\Local\Elite Software\Rhvac 10\499 Jay Windom RESIDENCE first and second floor.r10
 Project Title: 499 Jay Windom Martin Residence Hvac Design
 Designed By: Engr Rahaman
 Project Date: Friday, October 22, 2025
 Client Address: 499 Jay Windom Martin Residence
 Client City: 6406 Westover Dr. Granbury, TX.
 Company Address: 499 Jay Windom Martin Residence
 Company City: 6406 Westover Dr. Granbury, TX.
 Permit Number(s): HV2025001

Design Data

Reference City: Fort Worth Carswell AFB, Texas
 Building Orientation: Front door faces North
 Daily Temperature Range: Medium
 Latitude: 32 Degrees
 Elevation: 650 ft.
 Altitude Factor: 0.977

| | Outdoor <u>Dry Bulb</u> | Outdoor <u>Wet Bulb</u> | Outdoor <u>Rel.Hum</u> | Indoor <u>Rel.Hum</u> | Indoor <u>Dry Bulb</u> | Grains <u>Difference</u> |
|---------|----------------------------|----------------------------|---------------------------|--------------------------|---------------------------|-----------------------------|
| Winter: | 40 | 20.42 | 0% | 30% | 72 | 46.90 |
| Summer: | 100 | 74 | 30% | 50% | 75 | 21 |

Check Figures

| | | | |
|-----------------------------|--------|---------------------|-------|
| Total Building Supply CFM: | 2,461 | CFM Per Square ft.: | 0.852 |
| Square ft. of Room Area: | 2,889 | Square ft. Per Ton: | 583 |
| Volume (ft³) (Above Grade): | 26,050 | | |
| Volume (ft³) (Total): | 26,050 | | |

Building Loads

| | | |
|---|-------------|--|
| Total Heating Required Including Ventilation Air: | 27,275 Btuh | 27.275 MBH |
| Total Sensible Gain: | 52,884 Btuh | 89 % |
| Total Latent Gain: | 6,540 Btuh | 11 % |
| Total Cooling Required Including Ventilation Air: | 59,424 Btuh | 4.95 Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.
 Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.
 All computed results are estimates as building use and weather may vary.
 Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



Load Preview Report

| Scope | Has AED | Net Ton | ft. ² /Ton | Area | Sen Gain | Lat Gain | Net Gain | Sen Loss | Min Htg CFM | Min Clg CFM | Sys Htg CFM | Sys Clg CFM | Sys Act CFM | |
|-------------------------------|---------|---------|-----------------------|-------|----------|----------|----------|----------|-------------|-------------|-------------|-------------|-------------|-------|
| Building | | 4.95 | 583 | 2,889 | 52,884 | 6,540 | 59,424 | 27,275 | 363 | 2,461 | 363 | 2,461 | 2,461 | |
| System 1 Main Floor | Yes | 4.95 | 583 | 2,889 | 52,884 | 6,540 | 59,424 | 27,275 | 363 | 2,461 | 363 | 2,461 | 2,461 | 17x24 |
| Zone 1 | | | | 2,889 | 52,884 | 6,540 | 59,424 | 27,275 | 363 | 2,461 | 363 | 2,461 | 2,461 | 17x24 |
| 1-Main Floor Entrance | | | | 340 | 5,189 | 0 | 5,189 | 3,578 | 48 | 241 | 48 | 241 | 241 | 1-9 |
| 2-Main Floor Office | | | | 140 | 6,596 | 860 | 7,456 | 3,349 | 45 | 307 | 45 | 307 | 307 | 1-10 |
| 3-Main Floor Kitchen | | | | 230 | 4,752 | 0 | 4,752 | 3,134 | 42 | 221 | 42 | 221 | 221 | 1-9 |
| 4-Main Floor Dinning | | | | 280 | 6,168 | 920 | 7,088 | 3,327 | 44 | 287 | 44 | 287 | 287 | 1-10 |
| 5-Main Floor Living | | | | 300 | 7,354 | 1,550 | 8,904 | 3,405 | 45 | 342 | 45 | 342 | 342 | 1-10 |
| 6-Main Floor Pantry | | | | 24 | 817 | 100 | 917 | 198 | 3 | 38 | 3 | 38 | 38 | 1-5 |
| 7-Main Floor Powder | | | | 25 | 1,162 | 230 | 1,392 | 200 | 3 | 54 | 3 | 54 | 54 | 1-5 |
| 8-Main Floor Rear Entrance | | | | 130 | 1,407 | 0 | 1,407 | 981 | 13 | 65 | 13 | 65 | 65 | 1-6 |
| 9-Second Floor Laundry | | | | 130 | 1,952 | 500 | 2,452 | 576 | 8 | 91 | 8 | 91 | 91 | 1-6 |
| 10-Second Floor Dressing Room | | | | 170 | 1,972 | 0 | 1,972 | 1,368 | 18 | 92 | 18 | 92 | 92 | 1-6 |
| 11-Second Floor Masterbed | | | | 240 | 4,574 | 960 | 5,534 | 1,749 | 23 | 213 | 23 | 213 | 213 | 1-9 |
| 12-Second Floor Master Bath | | | | 180 | 1,159 | 0 | 1,159 | 756 | 10 | 54 | 10 | 54 | 54 | 1-5 |
| 13-Second Floor Bedroom 2 | | | | 180 | 3,280 | 760 | 4,040 | 1,340 | 18 | 153 | 18 | 153 | 153 | 1-8 |
| 14-Second Floor Bathroom | | | | 90 | 1,018 | 0 | 1,018 | 579 | 8 | 47 | 8 | 47 | 47 | 1-5 |
| 15-Second Floor Bedroom-3 | | | | 170 | 3,653 | 660 | 4,313 | 1,693 | 23 | 170 | 23 | 170 | 170 | 1-8 |
| 16-Second Floor Hallway | | | | 260 | 1,831 | 0 | 1,831 | 1,042 | 14 | 85 | 14 | 85 | 85 | 1-6 |



Duct Size Preview

| Room or Duct Name | Source | Minimum Velocity | Maximum Velocity | Rough Factor | Design L/100 | SP Loss | Duct Velocity | Duct Length | Htg Flow | Clg Flow | Act. Flow | Duct Size | Reg Size |
|--------------------------------|----------|------------------|------------------|--------------|--------------|---------|---------------|-------------|----------|----------|-----------|-----------|----------|
| System 1 | | | | | | | | | | | | | |
| Supply Runouts | | | | | | | | | | | | | |
| Zone 1 | | | | | | | | | | | | | |
| 1-Main Floor Entrance | Built-In | 0 | 750 | 0.01 | 0.1 | | 546.6 | | 48 | 241 | 241 | 1-9 | |
| 2-Main Floor Office | Built-In | 0 | 750 | 0.01 | 0.1 | | 562.8 | | 45 | 307 | 307 | 1-10 | |
| 3-Main Floor Kitchen | Built-In | 0 | 750 | 0.01 | 0.1 | | 500.6 | | 42 | 221 | 221 | 1-9 | |
| 4-Main Floor Dinning | Built-In | 0 | 750 | 0.01 | 0.1 | | 526.3 | | 44 | 287 | 287 | 1-10 | |
| 5-Main Floor Living | Built-In | 0 | 750 | 0.01 | 0.1 | | 627.5 | | 45 | 342 | 342 | 1-10 | |
| 6-Main Floor Pantry | Built-In | 0 | 750 | 0.01 | 0.1 | | 278.8 | | 3 | 38 | 38 | 1-5 | |
| 7-Main Floor Powder | Built-In | 0 | 750 | 0.01 | 0.1 | | 396.6 | | 3 | 54 | 54 | 1-5 | |
| 8-Main Floor Rear Enteran | Built-In | 0 | 750 | 0.01 | 0.1 | | 333.5 | | 13 | 65 | 65 | 1-6 | |
| 9-Second Floor Laundry | Built-In | 0 | 750 | 0.01 | 0.1 | | 462.7 | | 8 | 91 | 91 | 1-6 | |
| 10-Second Floor Dressing Room | Built-In | 0 | 750 | 0.01 | 0.1 | | 467.3 | | 18 | 92 | 92 | 1-6 | |
| 11-Second Floor Masterbe | Built-In | 0 | 750 | 0.01 | 0.1 | | 481.8 | | 23 | 213 | 213 | 1-9 | |
| 12-Second Floor Master B& | Built-In | 0 | 750 | 0.01 | 0.1 | | 395.6 | | 10 | 54 | 54 | 1-5 | |
| 13-Second Floor Bedroom | Built-In | 0 | 750 | 0.01 | 0.1 | | 437.3 | | 18 | 153 | 153 | 1-8 | |
| 14-Second Floor Bathroom | Built-In | 0 | 750 | 0.01 | 0.1 | | 347.4 | | 8 | 47 | 47 | 1-5 | |
| 15-Second Floor Bedroom | Built-In | 0 | 750 | 0.01 | 0.1 | | 487 | | 23 | 170 | 170 | 1-8 | |
| 16-Second Floor Hallway | Built-In | 0 | 750 | 0.01 | 0.1 | | 434 | | 14 | 85 | 85 | 1-6 | |
| Other Ducts in System 1 | | | | | | | | | | | | | |
| Supply Main Trunk | Built-In | 0 | 900 | 0.003 | 0.1 | | 868.6 | | 363 | 2,461 | 2,461 | 17x24 | |

Summary

System 1


Heating Flow: 363

Cooling Flow: 2461



System 1 - Main Floor - Adequate Exposure Diversity Test

Test For Adequate Exposure Diversity



AED Calculation Summary

--- SYSTEM HAS ADEQUATE EXPOSURE DIVERSITY. ---

System is on N, E, S, W rosette.

Peak load exceeds 12-hour average load by 16.6%.


AED Excursion (amount by which peak exceeds 1.3 x average): 0 Btuh

Definition: A system has adequate exposure diversity if the peak-hour glass load for the entire conditioned space does not exceed the average glass load for the entire conditioned space by more than 30 percent.



System 1 - Main Floor - Psychrometric Chart

| Name | Description | DB | WB | Name | Description | DB | WB |
|------|--------------------------|-----|------|------|-------------------------|-----|------|
| RC | Room Condition | 75 | 62.4 | OC | Outdoor Condition | n/a | n/a |
| LC | Leaving Coil Condition | 55 | 54.1 | ECC | Entering Coil Condition | 75 | 62.4 |
| SD | Supply Duct Gain | n/a | n/a | DTF | Draw-thru Fan S.Gain | n/a | n/a |
| RD | Return Duct Gain | n/a | n/a | MIX | Mixed Air Point | n/a | n/a |
| RML | Return Misc Latent | n/a | n/a | ML | Supply Misc Latent | n/a | n/a |
| RMS | Return Misc Sensible | n/a | n/a | MS | Supply Misc Sensible | n/a | n/a |
| HRV | Heat Recovery Ventilator | n/a | n/a | | | | |





Total Building Summary Loads

| Component Description | Area Quan | Sen Loss | Lat Gain | Sen Gain | Total Gain |
|--|-----------|---------------|--------------|---------------|---------------|
| 1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62 | 849 | 14,943 | 0 | 22,517 | 22,517 |
| 11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28 | 69 | 618 | 0 | 696 | 696 |
| Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043 | 3178 | 4,412 | 0 | 3,027 | 3,027 |
| 16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, U-value 0.026 | 2889 | 2,403 | 0 | 6,007 | 6,007 |
| 19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072 | 2989 | 4,899 | 0 | 3,828 | 3,828 |
| Subtotals for structure: | | 27,275 | 0 | 36,075 | 36,075 |
| People: | 18 | | 4,140 | 5,400 | 9,540 |
| Equipment: | | | 2,400 | 5,100 | 7,500 |
| Lighting: | 1850 | | | 6,309 | 6,309 |
| Ductwork: | | 0 | 0 | 0 | 0 |
| Infiltration: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| Ventilation: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| Total Building Load Totals: | | 27,275 | 6,540 | 52,884 | 59,424 |

Check Figures

| | | | |
|-----------------------------|--------|---------------------|-------|
| Total Building Supply CFM: | 2,461 | CFM Per Square ft.: | 0.852 |
| Square ft. of Room Area: | 2,889 | Square ft. Per Ton: | 583 |
| Volume (ft³) (Above Grade): | 26,050 | | |
| Volume (ft³) (Total): | 26,050 | | |

Building Loads



| | | |
|---|-------------|--|
| Total Heating Required Including Ventilation Air: | 27,275 Btuh | 27.275 MBH |
| Total Sensible Gain: | 52,884 Btuh | 89 % |
| Total Latent Gain: | 6,540 Btuh | 11 % |
| Total Cooling Required Including Ventilation Air: | 59,424 Btuh | 4.95 Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.
All computed results are estimates as building use and weather may vary.
Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.





Building Pie Chart





Building Bar Graph





System 1 Main Floor Summary Loads

| Component Description | Area Quan | Sen Loss | Lat Gain | Sen Gain | Total Gain |
|--|-----------|---------------|--------------|---------------|---------------|
| 1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62 | 849 | 14,943 | 0 | 22,517 | 22,517 |
| 11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28 | 69 | 618 | 0 | 696 | 696 |
| Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043 | 3178 | 4,412 | 0 | 3,027 | 3,027 |
| 16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, U-value 0.026 | 2889 | 2,403 | 0 | 6,007 | 6,007 |
| 19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072 | 2989 | 4,899 | 0 | 3,828 | 3,828 |
| Subtotals for structure: | | 27,275 | 0 | 36,075 | 36,075 |
| People: | 18 | | 4,140 | 5,400 | 9,540 |
| Equipment: | | | 2,400 | 5,100 | 7,500 |
| Lighting: | 1850 | | | 6,309 | 6,309 |
| Ductwork: | | 0 | 0 | 0 | 0 |
| Infiltration: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| Ventilation: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| System 1 Main Floor Load Totals: | | 27,275 | 6,540 | 52,884 | 59,424 |

Check Figures

| | | | |
|-----------------------------|--------|---------------------|-------|
| Supply CFM: | 2,461 | CFM Per Square ft.: | 0.852 |
| Square ft. of Room Area: | 2,889 | Square ft. Per Ton: | 583 |
| Volume (ft³) (Above Grade): | 26,050 | | |
| Volume (ft³) (Total): | 26,050 | | |

System Loads

| | | |
|---|-------------|--|
| Total Heating Required Including Ventilation Air: | 27,275 Btuh | 27.275 MBH |
| Total Sensible Gain: | 52,884 Btuh | 89 % |
| Total Latent Gain: | 6,540 Btuh | 11 % |
| Total Cooling Required Including Ventilation Air: | 59,424 Btuh | 4.95 Tons (Based On Sensible + Latent) |


Notes

Rhvac is an ACCA approved Manual J, D and S computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.
All computed results are estimates as building use and weather may vary.
Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.




System 1 Main Floor Pie Chart

System
1 Main
Floor
Loss
27,275
Btuh





System
1 Main
Floor
Gain
59,424
Btuh





System 1 Main Floor Bar Graph





Equipment Data - System 1 - Main Floor

Cooling

| | |
|-----------------------------|---|
| System Type: | Standard Air Conditioner |
| Outdoor Model: | Heat Pump:CHPE4860D4+.outdoor unit:GSX160611F |
| Outdoor Manufacturer: | GOODMAN |
| Description: | 0 |
| Nominal Capacity: | 60,000 |
| Adjusted Capacity: | 60000 |
| Adjusted Sensible Capacity: | 60000 |
| Efficiency: | 16 SEER |

Heating

| | |
|---------------|---|
| System Type: | Electric Resistance |
| Model: | Heat Pump Indoor:CHPE4860D4+.outdoor unit:GSZH506010A |
| Manufacturer: | GOODMAN |
| Description: | 0 |
| Capacity: | 60,000 |
| Efficiency: | 0% |

This system's equipment was selected in accordance with ACCA Manual S.

Manual S equipment sizing data: SODB: 100F, SOWB: 74F, WODB: 40F, SIDB: 75F, SIRH: 50%, WIDB: 72F, Sen. gain: 52,884 Btuh, Lat. gain: 6,540 Btuh, Sen. loss: 27,275 Btuh, Entering clg. coil DB: 75F, Entering clg. coil WB: 62.4F, Entering htg. coil DB: 72F, Clg. coil TD: 20F, Htg. coil TD: 70F, Req. clg. airflow: 2461 CFM, Req. htg. airflow: 363 CFM



Manual S Performance Data - System 1 - Main Floor

Loads and Design Conditions

Cooling:

| | | | |
|-------------------|-------|--------------------|--------|
| Outdoor Dry Bulb: | 100 | Sensible Gain: | 52.884 |
| Outdoor Wet Bulb: | 74 | Latent Gain: | 6.540 |
| Indoor Dry Bulb: | 75 | Total Gain: | 59.424 |
| Indoor RH: | 50 | Load SHR: | 0.89 |
| Supply Airflow: | 2,461 | Entering Dry Bulb: | 75 |
| | | Entering Wet Bulb: | 62.4 |

Heating:

| | | | |
|-------------------|----|--------------------|--------|
| Outdoor Dry Bulb: | 40 | Sensible Loss: | 27.275 |
| Indoor Dry Bulb: | 72 | Entering Dry Bulb: | 72.0 |
| Indoor RH: | 30 | Supply Airflow: | 363 |

Equipment Performance Data at System Design Conditions

This system's equipment was selected in accordance with ACCA Manual S.

Cooling:

Model Type: Standard Air Conditioner, Model: Heat Pump:CHPE4860D4+.outdoor unit:GSX160611F
Nominal Capacity: 60.000, Manufacturer: GOODMAN

Entered Interpolation Data:

| EWB °F | Air Flow CFM | ODB °F | Total Capacity MBtuh | Power Input kW | EDB 75 °F | |
|-----------|-----------------|-----------|----------------------------|----------------------|--------------|-------------------------------|
| | | | | | S/T | Sensible Capacity MBtuh |
| 62.40512 | 2461 | 100 | 60 | 0 | 1 | 60 |

Interpolation Results:

| | | <u>Load</u> | <u>Percent of Load</u> |
|--------------------|--------|-------------|----------------------------|
| Sensible Capacity: | 60.000 | 52.884 | 113% |
| Latent Capacity: | 0.000 | 6.540 | 0% |
| Total Capacity: | 60.000 | 59.424 | 101% |

Heating:

Model Type: Electric Resistance, Model: Heat Pump Indoor:CHPE4860D4+.outdoor unit:GSZH506010A, Nominal Capacity: 60.000, Manufacturer: GOODMAN


Results:

| | | <u>Load</u> | <u>Percent of Load</u> |
|-------------------|--------|-------------|----------------------------|
| Heating Capacity: | 60.000 | 27.275 | 220% |



System 1 - Hourly Room Net Gain

System 1 Hourly Room Net Gain



- Main Floor Entrance (61%)
- Main Floor Office (52%)
- ▲ Main Floor Kitchen (73%)
- ◆ Main Floor Dinning (49%)
- Main Floor Living (39%)
- Main Floor Pantry (0%)
- Main Floor Powder (0%)
- Main Floor Rear Entrance (0%)
- ▼ Second Floor Laundry (0%)
- × Second Floor Dressing Room (54%)
- ▲ Second Floor Masterbed (23%)
- Second Floor Master Bath (0%)
- ▼ Second Floor Bedroom 2 (24%)
- Second Floor Bathroom (23%)
- Second Floor Bedroom-3 (37%)
- ▲ Second Floor Hallway (0%)

Note: Glass gain as a percent of net gain is shown in parenthesis. Although floor, roof, wall and door gains also vary throughout the day, for this graph and in Manual J glass gains are the only ones that fluctuate.



System 1, Zone 1 Summary Loads (Average Load Procedure for Rooms)

| Component Description | Area Quan | Sen Loss | Lat Gain | Sen Gain | Total Gain |
|--|-----------|----------|----------|----------|------------|
| 1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62 | 849 | 14,943 | 0 | 22,517 | 22,517 |
| 11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28 | 69 | 618 | 0 | 696 | 696 |
| Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043 | 3178 | 4,412 | 0 | 3,027 | 3,027 |
| 16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, U-value 0.026 | 2889 | 2,403 | 0 | 6,007 | 6,007 |
| 19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072 | 2989 | 4,899 | 0 | 3,828 | 3,828 |
| Subtotals for structure: | | 27,275 | 0 | 36,075 | 36,075 |
| People: | 18 | | 4,140 | 5,400 | 9,540 |
| Equipment: | | | 2,400 | 5,100 | 7,500 |
| Lighting: | 1850 | | | 6,309 | 6,309 |
| Ductwork: | | 0 | 0 | 0 | 0 |
| Infiltration: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| System 1, Zone 1 Load Totals: | | 27,275 | 6,540 | 52,884 | 59,424 |

Check Figures

| | | | |
|-----------------------------|--------|---------------------|-------|
| Supply CFM: | 2,461 | CFM Per Square ft.: | 0.852 |
| Square ft. of Room Area: | 2,889 | Square ft. Per Ton: | 583 |
| Volume (ft³) (Above Grade): | 26,050 | | |
| Volume (ft³) (Total): | 26,050 | | |

Zone Loads

| | | |
|-------------------------|-------------|--|
| Total Heating Required: | 27,275 Btuh | 27.275 MBH |
| Total Sensible Gain: | 52,884 Btuh | 89 % |
| Total Latent Gain: | 6,540 Btuh | 11 % |
| Total Cooling Required: | 59,424 Btuh | 4.95 Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.
All computed results are estimates as building use and weather may vary.
Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



Detailed Room Loads - Room 1 - Main Floor Enterance (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 34.0 ft. | Zone Number: | 1 |
| Area: | 340.0 sq.ft. | Supply Air: | 241 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 4.3 AC/hr |
| Volume: | 3,400 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 241 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 9 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 547 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 547 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.107 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|---------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 34 X 10 | 196 | 0.043 | 1.4 | 272 | 1.0 | 0 | 187 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Door-11F 3 X 8 | 24 | 0.280 | 9.0 | 215 | 10.1 | 0 | 242 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 120 | 0.550 | 17.6 | 2,112 | 26.5 | 0 | 3,182 |
| UP-Ceil-16A-38 10 X 34 | 340 | 0.026 | 0.8 | 283 | 2.1 | 0 | 707 |
| Floor-19A1-11op 34 X 10 | 340 | 0.072 | 1.6 | 557 | 1.3 | 0 | 435 |
| Subtotals for Structure: | | | | 3,578 | | 0 | 4,848 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 440 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 3,578 | | 0 | 5,189 |



Detailed Room Loads - Room 2 - Main Floor Office (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|------------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 14.0 ft. | Zone Number: | 1 |
| Area: | 140.0 sq.ft. | Supply Air: | 307 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 13.2 AC/hr |
| Volume: | 1,400 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 307 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 10 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 563 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 563 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.099 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 24 X 10 | 94 | 0.043 | 1.4 | 131 | 1.0 | 0 | 90 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 130 | 0.550 | 17.6 | 2,288 | 26.5 | 0 | 3,448 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 16 | 0.550 | 17.6 | 282 | 26.5 | 0 | 424 |
| UP-Ceil-16A-38 10 X 14 | 140 | 0.026 | 0.8 | 116 | 2.1 | 0 | 291 |
| Floor-19A1-11op 24 X 10 | 240 | 0.072 | 1.6 | 393 | 1.3 | 0 | 307 |
| Subtotals for Structure: | | | | 3,349 | | 0 | 4,655 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 340 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 2 | | | | | 460 | 600 |
| Equipment: | | | | | | 400 | 1,000 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 3,349 | | 860 | 6,596 |



Detailed Room Loads - Room 3 - Main Floor Kitchen (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 23.0 ft. | Zone Number: | 1 |
| Area: | 230.0 sq.ft. | Supply Air: | 221 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 5.8 AC/hr |
| Volume: | 2,300 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 221 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 9 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 501 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 501 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.090 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|---------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 23 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 130 | 0.550 | 17.6 | 2,288 | 26.5 | 0 | 3,448 |
| UP-Ceil-16A-38 10 X 23 | 230 | 0.026 | 0.8 | 191 | 2.1 | 0 | 478 |
| Floor-19A1-11op 23 X 10 | 230 | 0.072 | 1.6 | 377 | 1.3 | 0 | 295 |
| Subtotals for Structure: | | | | 3,134 | | 0 | 4,411 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 330 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 3,134 | | 0 | 4,752 |



Detailed Room Loads - Room 4 - Main Floor Dinning (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 28.0 ft. | Zone Number: | 1 |
| Area: | 280.0 sq.ft. | Supply Air: | 287 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 6.2 AC/hr |
| Volume: | 2,800 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 287 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 10 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 526 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 526 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.086 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|----------|---------|--------------|---------|------------|--------------|
| N -Wall-Frame wall-R-23 28 X 10 | 150 | 0.043 | 1.4 | 208 | 1.0 | 0 | 143 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 130 | 0.550 | 17.6 | 2,288 | 26.5 | 0 | 3,448 |
| UP-Ceil-16A-38 10 X 28 | 280 | 0.026 | 0.8 | 233 | 2.1 | 0 | 582 |
| Floor-19A1-11op 28 X 10 | 280 | 0.072 | 1.6 | 459 | 1.3 | 0 | 359 |
| Subtotals for Structure: | | | | 3,327 | | 0 | 4,627 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 380 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 4 | | | | | 920 | 1,200 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 3,327 | | 920 | 6,168 |



Detailed Room Loads - Room 5 - Main Floor Living (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 30.0 ft. | Zone Number: | 1 |
| Area: | 300.0 sq.ft. | Supply Air: | 342 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 6.8 AC/hr |
| Volume: | 3,000 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 342 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 10 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 627 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 627 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.122 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|----------|---------|--------------|---------|--------------|--------------|
| N -Wall-Frame wall-R-23 30 X 10 | 170 | 0.043 | 1.4 | 236 | 1.0 | 0 | 162 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 130 | 0.550 | 17.6 | 2,288 | 26.5 | 0 | 3,448 |
| UP-Ceil-16A-38 10 X 30 | 300 | 0.026 | 0.8 | 250 | 2.1 | 0 | 624 |
| Floor-19A1-11op 30 X 10 | 300 | 0.072 | 1.6 | 492 | 1.3 | 0 | 384 |
| Subtotals for Structure: | | | | 3,405 | | 0 | 4,713 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 400 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 5 | | | | | 1,150 | 1,500 |
| Equipment: | | | | | | 400 | 800 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 3,405 | | 1,550 | 7,354 |



Detailed Room Loads - Room 6 - Main Floor Pantry (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 4.0 ft. | System Number: | 1 |
| Room Width: | 6.0 ft. | Zone Number: | 1 |
| Area: | 24.0 sq.ft. | Supply Air: | 38 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 9.5 AC/hr |
| Volume: | 240 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 38 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 5 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 279 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 279 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.064 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 6 X 10 | 60 | 0.043 | 1.4 | 83 | 1.0 | 0 | 57 |
| E -Wall-Frame wall-R-23 4 X 10 | 40 | 0.043 | 1.4 | 56 | 1.0 | 0 | 38 |
| UP-Ceil-16A-38 4 X 6 | 24 | 0.026 | 0.8 | 20 | 2.1 | 0 | 50 |
| Floor-19A1-11op 6 X 4 | 24 | 0.072 | 1.6 | 39 | 1.3 | 0 | 31 |
| Subtotals for Structure: | | | | 198 | | 0 | 176 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 100 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Equipment: | | | | | | 100 | 300 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 198 | | 100 | 817 |



Detailed Room Loads - Room 7 - Main Floor Powder (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|------------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 5.0 ft. | System Number: | 1 |
| Room Width: | 5.0 ft. | Zone Number: | 1 |
| Area: | 25.0 sq.ft. | Supply Air: | 54 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 13.0 AC/hr |
| Volume: | 250 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 54 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 5 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 397 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 397 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.128 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|----------|---------|------------|---------|------------|--------------|
| N -Wall-Frame wall-R-23 5 X 10 | 50 | 0.043 | 1.4 | 69 | 1.0 | 0 | 48 |
| E -Wall-Frame wall-R-23 5 X 10 | 50 | 0.043 | 1.4 | 69 | 1.0 | 0 | 48 |
| UP-Ceil-16A-38 5 X 5 | 25 | 0.026 | 0.8 | 21 | 2.1 | 0 | 52 |
| Floor-19A1-11op 5 X 5 | 25 | 0.072 | 1.6 | 41 | 1.3 | 0 | 32 |
| Subtotals for Structure: | | | | 200 | | 0 | 180 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 100 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 1 | | | | | 230 | 300 |
| Lighting: | 200 | | | | | | 682 |
| Room Totals: | | | | 200 | | 230 | 1,162 |



Detailed Room Loads - Room 8 - Main Floor Rear Enterance (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 13.0 ft. | System Number: | 1 |
| Room Width: | 10.0 ft. | Zone Number: | 1 |
| Area: | 130.0 sq.ft. | Supply Air: | 65 CFM |
| Ceiling Height: | 10.0 ft. | Supply Air Changes: | 3.0 AC/hr |
| Volume: | 1,300 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 65 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 6 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 333 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 333 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.071 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|---------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 13 X 10 | 85 | 0.043 | 1.4 | 118 | 1.0 | 0 | 81 |
| E -Wall-Frame wall-R-23 10 X 10 | 100 | 0.043 | 1.4 | 139 | 1.0 | 0 | 95 |
| N -Door-11F 3 X 8 | 24 | 0.280 | 9.0 | 215 | 10.1 | 0 | 242 |
| N -Door-11F 3 X 7 | 21 | 0.280 | 9.0 | 188 | 10.1 | 0 | 212 |
| UP-Ceil-16A-38 13 X 10 | 130 | 0.026 | 0.8 | 108 | 2.1 | 0 | 270 |
| Floor-19A1-11op 10 X 13 | 130 | 0.072 | 1.6 | 213 | 1.3 | 0 | 166 |
| Subtotals for Structure: | | | | 981 | | 0 | 1,066 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 230 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 981 | | 0 | 1,407 |



Detailed Room Loads - Room 9 - Second Floor Laundry (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 13.0 ft. | Zone Number: | 1 |
| Area: | 130.0 sq.ft. | Supply Air: | 91 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 5.2 AC/hr |
| Volume: | 1,040 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 91 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 6 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 463 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 463 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.135 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 13 X 8 | 104 | 0.043 | 1.4 | 144 | 1.0 | 0 | 99 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| UP-Ceil-16A-38 10 X 13 | 130 | 0.026 | 0.8 | 108 | 2.1 | 0 | 270 |
| Floor-19A1-11op 13 X 10 | 130 | 0.072 | 1.6 | 213 | 1.3 | 0 | 166 |
| Subtotals for Structure: | | | | 576 | | 0 | 611 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 184 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Equipment: | | | | | | 500 | 1,000 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 576 | | 500 | 1,952 |



Detailed Room Loads - Room 10 - Second Floor Dressing Room (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 17.0 ft. | Zone Number: | 1 |
| Area: | 170.0 sq.ft. | Supply Air: | 92 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 4.0 AC/hr |
| Volume: | 1,360 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 92 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 6 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 467 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 467 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.137 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 17 X 8 | 96 | 0.043 | 1.4 | 133 | 1.0 | 0 | 92 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 15 | 0.550 | 17.6 | 264 | 26.5 | 0 | 398 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 25 | 0.550 | 17.6 | 440 | 26.5 | 0 | 663 |
| UP-Ceil-16A-38 10 X 17 | 170 | 0.026 | 0.8 | 141 | 2.1 | 0 | 354 |
| Floor-19A1-11op 17 X 10 | 170 | 0.072 | 1.6 | 279 | 1.3 | 0 | 218 |
| Subtotals for Structure: | | | | 1,368 | | 0 | 1,801 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 216 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 50 | | | | | | 171 |
| Room Totals: | | | | 1,368 | | 0 | 1,972 |



Detailed Room Loads - Room 11 - Second Floor Masterbed (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 24.0 ft. | Zone Number: | 1 |
| Area: | 240.0 sq.ft. | Supply Air: | 213 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 6.7 AC/hr |
| Volume: | 1,920 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 213 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 9 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 482 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 482 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.084 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 24 X 8 | 144 | 0.043 | 1.4 | 200 | 1.0 | 0 | 137 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 48 | 0.550 | 17.6 | 845 | 26.5 | 0 | 1,273 |
| UP-Ceil-16A-38 10 X 24 | 240 | 0.026 | 0.8 | 200 | 2.1 | 0 | 499 |
| Floor-19A1-11op 24 X 10 | 240 | 0.072 | 1.6 | 393 | 1.3 | 0 | 307 |
| Subtotals for Structure: | | | | 1,749 | | 0 | 2,292 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 272 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 2 | | | | | 460 | 600 |
| Equipment: | | | | | | 500 | 1,000 |
| Lighting: | 200 | | | | | | 682 |
| Room Totals: | | | | 1,749 | | 960 | 4,574 |



Detailed Room Loads - Room 12 - Second Floor Master Bath (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 18.0 ft. | Zone Number: | 1 |
| Area: | 180.0 sq.ft. | Supply Air: | 54 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 2.2 AC/hr |
| Volume: | 1,440 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 54 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 5 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 396 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 396 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.127 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 18 X 8 | 144 | 0.043 | 1.4 | 200 | 1.0 | 0 | 137 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| UP-Ceil-16A-38 10 X 18 | 180 | 0.026 | 0.8 | 150 | 2.1 | 0 | 374 |
| Floor-19A1-11op 18 X 10 | 180 | 0.072 | 1.6 | 295 | 1.3 | 0 | 231 |
| Subtotals for Structure: | | | | 756 | | 0 | 818 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 224 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 756 | | 0 | 1,159 |



Detailed Room Loads - Room 13 - Second Floor Bedroom 2 (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 18.0 ft. | Zone Number: | 1 |
| Area: | 180.0 sq.ft. | Supply Air: | 153 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 6.4 AC/hr |
| Volume: | 1,440 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 153 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 8 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 437 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 437 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.081 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 18 X 8 | 108 | 0.043 | 1.4 | 150 | 1.0 | 0 | 103 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 36 | 0.550 | 17.6 | 634 | 26.5 | 0 | 955 |
| UP-Ceil-16A-38 10 X 18 | 180 | 0.026 | 0.8 | 150 | 2.1 | 0 | 374 |
| Floor-19A1-11op 18 X 10 | 180 | 0.072 | 1.6 | 295 | 1.3 | 0 | 231 |
| Subtotals for Structure: | | | | 1,340 | | 0 | 1,739 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 224 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 2 | | | | | 460 | 600 |
| Equipment: | | | | | | 300 | 600 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 1,340 | | 760 | 3,280 |



Detailed Room Loads - Room 14 - Second Floor Bathroom (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 9.0 ft. | System Number: | 1 |
| Room Width: | 10.0 ft. | Zone Number: | 1 |
| Area: | 90.0 sq.ft. | Supply Air: | 47 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 3.9 AC/hr |
| Volume: | 720 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 47 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 5 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 347 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 347 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.099 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 9 X 8 | 63 | 0.043 | 1.4 | 87 | 1.0 | 0 | 60 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 9 | 0.550 | 17.6 | 158 | 26.6 | 0 | 239 |
| UP-Ceil-16A-38 9 X 10 | 90 | 0.026 | 0.8 | 75 | 2.1 | 0 | 187 |
| Floor-19A1-11op 10 X 9 | 90 | 0.072 | 1.6 | 148 | 1.3 | 0 | 115 |
| Subtotals for Structure: | | | | 579 | | 0 | 677 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 152 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 579 | | 0 | 1,018 |



Detailed Room Loads - Room 15 - Second Floor Bedroom-3 (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 17.0 ft. | Zone Number: | 1 |
| Area: | 170.0 sq.ft. | Supply Air: | 170 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 7.5 AC/hr |
| Volume: | 1,360 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 170 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 8 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 487 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 487 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.100 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U- Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|-----------------------------------|---------------|-----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 17 X 8 | 76 | 0.043 | 1.4 | 106 | 1.0 | 0 | 73 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| N -Gls-1G-cm-s shgc-0.62 100%S | 60 | 0.550 | 17.6 | 1,056 | 26.5 | 0 | 1,591 |
| UP-Ceil-16A-38 10 X 17 | 170 | 0.026 | 0.8 | 141 | 2.1 | 0 | 354 |
| Floor-19A1-11op 17 X 10 | 170 | 0.072 | 1.6 | 279 | 1.3 | 0 | 218 |
| Subtotals for Structure: | | | | 1,693 | | 0 | 2,312 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 216 | | 0.000 | 0 | 0.000 | 0 | 0 |
| People: 230 lat/per, 300 sen/per: | 2 | | | | | 460 | 600 |
| Equipment: | | | | | | 200 | 400 |
| Lighting: | 100 | | | | | | 341 |
| Room Totals: | | | | 1,693 | | 660 | 3,653 |



Detailed Room Loads - Room 16 - Second Floor Hallway (Average Load Procedure)

General

| | | | |
|----------------------|----------------------|-----------------------|-----------|
| Calculation Mode: | Htg. & clg. | Occurrences: | 1 |
| Room Length: | 10.0 ft. | System Number: | 1 |
| Room Width: | 26.0 ft. | Zone Number: | 1 |
| Area: | 260.0 sq.ft. | Supply Air: | 85 CFM |
| Ceiling Height: | 8.0 ft. | Supply Air Changes: | 2.5 AC/hr |
| Volume: | 2,080 cu.ft. | Req. Vent. Clg: | 0 CFM |
| Number of Registers: | 1 | Actual Winter Vent.: | 0 CFM |
| Runout Air: | 85 CFM | Percent of Supply.: | 0 % |
| Runout Duct Size: | 6 in. | Actual Summer Vent.: | 0 CFM |
| Runout Air Velocity: | 434 ft./min. | Percent of Supply: | 0 % |
| Runout Air Velocity: | 434 ft./min. | Actual Winter Infil.: | 0 CFM |
| Actual Loss: | 0.119 in.wg./100 ft. | Actual Summer Infil.: | 0 CFM |

| Item Description | Area Quantity | -U-Value | Htg HTM | Sen Loss | Clg HTM | Lat Gain | Sen Gain |
|--------------------------------|---------------|----------|---------|----------|---------|----------|----------|
| N -Wall-Frame wall-R-23 26 X 8 | 208 | 0.043 | 1.4 | 289 | 1.0 | 0 | 199 |
| E -Wall-Frame wall-R-23 10 X 8 | 80 | 0.043 | 1.4 | 111 | 1.0 | 0 | 76 |
| UP-Ceil-16A-38 10 X 26 | 260 | 0.026 | 0.8 | 216 | 2.1 | 0 | 541 |
| Floor-19A1-11op 26 X 10 | 260 | 0.072 | 1.6 | 426 | 1.3 | 0 | 333 |
| Subtotals for Structure: | | | | 1,042 | | 0 | 1,149 |
| Infil.: Win.: 0.0, Sum.: 0.0 | 288 | | 0.000 | 0 | 0.000 | 0 | 0 |
| Lighting: | 200 | | | | | | 682 |
| Room Totals: | | | | 1,042 | | 0 | 1,831 |



System 1 Room Load Summary

| No | Room Name | Area SF | Htg Sens Btuh | Min Htg CFM | Run Duct Size | Run Duct Vel | Clg Sens Btuh | Clg Lat Btuh | Min Clg CFM | Act Sys CFM |
|----------------|----------------------------|---------|---------------|-------------|---------------|--------------|---------------|--------------|-------------|-------------|
| ---Zone 1--- | | | | | | | | | | |
| 1 | Main Floor Entrance | 340 | 3,578 | 48 | 1-9 | 547 | 5,189 | 0 | 241 | 241 |
| 2 | Main Floor Office | 140 | 3,349 | 45 | 1-10 | 563 | 6,596 | 860 | 307 | 307 |
| 3 | Main Floor Kitchen | 230 | 3,134 | 42 | 1-9 | 501 | 4,752 | 0 | 221 | 221 |
| 4 | Main Floor Dinning | 280 | 3,327 | 44 | 1-10 | 526 | 6,168 | 920 | 287 | 287 |
| 5 | Main Floor Living | 300 | 3,405 | 45 | 1-10 | 627 | 7,354 | 1,550 | 342 | 342 |
| 6 | Main Floor Pantry | 24 | 198 | 3 | 1-5 | 279 | 817 | 100 | 38 | 38 |
| 7 | Main Floor Powder | 25 | 200 | 3 | 1-5 | 397 | 1,162 | 230 | 54 | 54 |
| 8 | Main Floor Rear Entrance | 130 | 981 | 13 | 1-6 | 333 | 1,407 | 0 | 65 | 65 |
| 9 | Second Floor Laundry | 130 | 576 | 8 | 1-6 | 463 | 1,952 | 500 | 91 | 91 |
| 10 | Second Floor Dressing Room | 170 | 1,368 | 18 | 1-6 | 467 | 1,972 | 0 | 92 | 92 |
| 11 | Second Floor Masterbed | 240 | 1,749 | 23 | 1-9 | 482 | 4,574 | 960 | 213 | 213 |
| 12 | Second Floor Master Bath | 180 | 756 | 10 | 1-5 | 396 | 1,159 | 0 | 54 | 54 |
| 13 | Second Floor Bedroom 2 | 180 | 1,340 | 18 | 1-8 | 437 | 3,280 | 760 | 153 | 153 |
| 14 | Second Floor Bathroom | 90 | 579 | 8 | 1-5 | 347 | 1,018 | 0 | 47 | 47 |
| 15 | Second Floor Bedroom-3 | 170 | 1,693 | 23 | 1-8 | 487 | 3,653 | 660 | 170 | 170 |
| 16 | Second Floor Hallway | 260 | 1,042 | 14 | 1-6 | 434 | 1,831 | 0 | 85 | 85 |
| System 1 total | | 2,889 | 27,275 | 363 | | | 52,884 | 6,540 | 2,461 | 2,461 |

System 1 Main Trunk Size: 17x24 in.
 Velocity: 869 ft./min
 Loss per 100 ft.: 0.068 in.wg

Cooling System Summary

| | Cooling Tons | Sensible/Latent Split | Sensible Btuh | Latent Btuh | Total Btuh |
|---------------|--------------|-----------------------|---------------|-------------|------------|
| Net Required: | 4.95 | 89% / 11% | 52,884 | 6,540 | 59,424 |
| Actual: | 5.00 | | | | 60,000 |

Equipment Data

| | Heating System | Cooling System |
|-----------------------------|---|--|
| Type: | Electric Resistance | Standard Air Conditioner |
| Model: | Heat Pump Indoor:CHPE4860D4+.outdoor unit:GSZH506010A | Heat Pump:CHPE4860D4+.outdoor unit:GSX160611F |
| Indoor Model: | | |
| Brand: | | |
| Description: | 0 | 0 |
| Efficiency: | 0% | 16 SEER |
| Sound: | 0 | 0 |
| Capacity: | 60,000 Btuh | 60,000 Btuh |
| Adjusted Capacity: | n/a | 60,000 Btuh |
| Sensible Capacity: | n/a | 0 Btuh |
| Adjusted Sensible Capacity: | n/a | 60,000 Btuh |
| Latent Capacity: | n/a | 0 Btuh |



System 1 Room Load Summary (cont'd)

Equipment Data

This system's equipment was selected in accordance with ACCA Manual S.

Manual S equipment sizing data: SODB: 100F, SOWB: 74F, WODB: 40F, SIDB: 75F, SIRH: 50%, WIDB: 72F, Sen. gain: 52,884 Btuh, Lat. gain: 6,540 Btuh, Sen. loss: 27,275 Btuh, Entering clg. coil DB: 75F, Entering clg. coil WB: 62.4F, Entering htg. coil DB: 72F, Clg. coil TD: 20F, Htg. coil TD: 70F, Req. clg. airflow: 2461 CFM, Req. htg. airflow: 363 CFM



Building Rotation Duct Sizes

| Room or Duct Name | Direction Front door Faces | | | | | | | | | | | | | | | | Max Duct Size |
|--------------------------------|----------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|---------------|
| | N | | NE | | E | | SE | | S | | SW | | W | | NW | | |
| | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | Htg Flow | Clg Flow | |
| System 1 | | | | | | | | | | | | | | | | | |
| Supply Runouts | | | | | | | | | | | | | | | | | |
| Zone 1 | | | | | | | | | | | | | | | | | |
| 1-Main Floor Entrance | 48 | 241 | 48 | 405 | 48 | 457 | 48 | 323 | 48 | 259 | 48 | 419 | 48 | 592 | 48 | 500 | 1-13 |
| 2-Main Floor Office | 45 | 307 | 45 | 506 | 45 | 579 | 45 | 430 | 45 | 329 | 45 | 557 | 45 | 750 | 45 | 625 | 1-14 |
| 3-Main Floor Kitchen | 42 | 221 | 42 | 398 | 42 | 472 | 42 | 336 | 42 | 237 | 42 | 435 | 42 | 612 | 42 | 491 | 1-13 |
| 4-Main Floor Dining | 44 | 287 | 44 | 465 | 44 | 545 | 44 | 408 | 44 | 308 | 44 | 529 | 44 | 707 | 44 | 574 | 1-14 |
| 5-Main Floor Living | 45 | 342 | 45 | 521 | 45 | 607 | 45 | 468 | 45 | 367 | 45 | 608 | 45 | 786 | 45 | 643 | 1-14 |
| 6-Main Floor Pantry | 3 | 38 | 3 | 39 | 3 | 42 | 3 | 42 | 3 | 41 | 3 | 54 | 3 | 55 | 3 | 48 | 1-5 |
| 7-Main Floor Powder | 3 | 54 | 3 | 55 | 3 | 60 | 3 | 59 | 3 | 58 | 3 | 77 | 3 | 78 | 3 | 68 | 1-6 |
| 8-Main Floor Rear Entrance | 13 | 65 | 13 | 67 | 13 | 73 | 13 | 72 | 13 | 70 | 13 | 93 | 13 | 94 | 13 | 82 | 1-6 |
| 9-Second Floor Laundry | 8 | 91 | 8 | 92 | 8 | 101 | 8 | 100 | 8 | 97 | 8 | 129 | 8 | 131 | 8 | 114 | 1-7 |
| 10-Second Floor Dressing Rm | 18 | 92 | 18 | 146 | 18 | 144 | 18 | 101 | 18 | 98 | 18 | 131 | 18 | 187 | 18 | 181 | 1-8 |
| 11-Second Floor Masterbed | 23 | 213 | 23 | 280 | 23 | 299 | 23 | 238 | 23 | 228 | 23 | 309 | 23 | 387 | 23 | 346 | 1-11 |
| 12-Second Floor Master Bath | 10 | 54 | 10 | 55 | 10 | 60 | 10 | 59 | 10 | 58 | 10 | 77 | 10 | 78 | 10 | 68 | 1-6 |
| 13-Second Floor Bedroom 2 | 18 | 153 | 18 | 203 | 18 | 216 | 18 | 171 | 18 | 164 | 18 | 222 | 18 | 280 | 18 | 251 | 1-10 |
| 14-Second Floor Bathroom | 8 | 47 | 8 | 60 | 8 | 54 | 8 | 52 | 8 | 51 | 8 | 67 | 8 | 70 | 8 | 74 | 1-6 |
| 15-Second Floor Bedroom-3 | 23 | 170 | 23 | 253 | 23 | 266 | 23 | 192 | 23 | 182 | 23 | 249 | 23 | 345 | 23 | 312 | 1-10 |
| 16-Second Floor Hallway | 14 | 85 | 14 | 87 | 14 | 95 | 14 | 94 | 14 | 91 | 14 | 121 | 14 | 123 | 14 | 107 | 1-7 |
| Other Ducts in System 1 | | | | | | | | | | | | | | | | | |
| Supply Main Trunk | 363 | 2,461 | 363 | 3,632 | 363 | 4,070 | 363 | 3,143 | 363 | 2,641 | 363 | 4,077 | 363 | 5,275 | 363 | 4,483 | 25x34 |
| Bldg. High Dir.: West | | | | | | | | | | | | | | | | | |
| Sensible Gain: 113,360 | | | | | | | | | | | | | | | | | |
| Latent Gain: 6,540 | | | | | | | | | | | | | | | | | |

Summary

System 1

Heating Flow: 363

Cooling Flow: 2461



Building Rotation Report

All rotation degree values in this report are clockwise with respect to the project's original orientation.
Building orientation as entered (zero degrees rotation): Front door faces North

Individual Rooms

| Rm. No. | Room Name | 0° Rot. CFM | 45° Rot. CFM | 90° Rot. CFM | 135° Rot. CFM | 180° Rot. CFM | 225° Rot. CFM | 270° Rot. CFM | 315° Rot. CFM | High Duct Size |
|---------|-----------|-------------|--------------|--------------|---------------|---------------|---------------|---------------|---------------|----------------|
|---------|-----------|-------------|--------------|--------------|---------------|---------------|---------------|---------------|---------------|----------------|

System 1:

Zone 1:

| | | | | | | | | | | |
|----|----------------------------|-----|-----|-----|-----|-----|-----|------|-----|-------|
| 1 | Main Floor Entrance | 241 | 405 | 457 | 323 | 259 | 419 | *592 | 500 | 1--13 |
| 2 | Main Floor Office | 307 | 506 | 579 | 430 | 329 | 557 | *750 | 625 | 1--14 |
| 3 | Main Floor Kitchen | 221 | 398 | 472 | 336 | 237 | 435 | *612 | 491 | 1--13 |
| 4 | Main Floor Dinning | 287 | 465 | 545 | 408 | 308 | 529 | *707 | 574 | 1--14 |
| 5 | Main Floor Living | 342 | 521 | 607 | 468 | 367 | 608 | *786 | 643 | 1--14 |
| 6 | Main Floor Pantry | 38 | 39 | 42 | 42 | 41 | 54 | *55 | 48 | 1--5 |
| 7 | Main Floor Powder | 54 | 55 | 60 | 59 | 58 | 77 | *78 | 68 | 1--6 |
| 8 | Main Floor Rear Entrance | 65 | 67 | 73 | 72 | 70 | 93 | *94 | 82 | 1--6 |
| 9 | Second Floor Laundry | 91 | 92 | 101 | 100 | 97 | 129 | *131 | 114 | 1--7 |
| 10 | Second Floor Dressing Room | 92 | 146 | 144 | 101 | 98 | 131 | *187 | 181 | 1--8 |
| 11 | Second Floor Masterbed | 213 | 280 | 299 | 238 | 228 | 309 | *387 | 346 | 1--11 |
| 12 | Second Floor Master Bath | 54 | 55 | 60 | 59 | 58 | 77 | *78 | 68 | 1--6 |
| 13 | Second Floor Bedroom 2 | 153 | 203 | 216 | 171 | 164 | 222 | *280 | 251 | 1--10 |
| 14 | Second Floor Bathroom | 47 | 60 | 54 | 52 | 51 | 67 | 70 | *74 | 1--6 |
| 15 | Second Floor Bedroom-3 | 170 | 253 | 266 | 192 | 182 | 249 | *345 | 312 | 1--10 |
| 16 | Second Floor Hallway | 85 | 87 | 95 | 94 | 91 | 121 | *123 | 107 | 1--7 |

* Indicates highest CFM of all rotations.

Whole Building


| Rotation Degrees | Front door Faces | Supply CFM | Sensible Gain | Latent Gain | Net Tons |
|------------------|------------------|------------|---------------|-------------|----------|
| 0° | North | 2,461 | 52,884 | *6,540 | 4.95 |
| 45° | Northeast | 3,632 | 78,050 | 6,540 | 7.05 |
| 90° | East | 4,070 | 87,464 | 6,540 | 7.83 |
| 135° | Southeast | 3,143 | 67,546 | 6,540 | 6.17 |
| 180° | South | 2,641 | 56,758 | 6,540 | 5.27 |
| 225° | Southwest | 4,077 | 87,598 | 6,540 | 7.84 |
| 270° | West | *5,275 | *113,360 | 6,540 | *9.99 |
| 315° | Northwest | 4,483 | 96,339 | 6,540 | 8.57 |

* Indicates highest value of all rotations.



Building Rotation Report (cont'd)

Building Rotation Tonnage




—●— Building Net Tonnage



Building Rotation Report (cont'd)

Building Rotation Hourly Net Gain



- ▲ Front door faces North
- Front door faces Northeast
- Front door faces East
- ◆ Front door faces Southeast
- Front door faces South
- ▲ Front door faces Southwest
- Front door faces West
- Front door faces Northwest



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1.01
8 Mar 10

County, Town, Municipality, Jurisdiction
Header Information

Contractor John Doe
Mechanical License # 12345
Building Plan # _____
Home Address (Street or Lot#, Block, Subdivision) _____

REQUIRED ATTACHMENTS¹ ATTACHED
Manual J1 Form (and supporting worksheets): Yes No
or MJ1AE Form² (and supporting worksheets): Yes No
OEM performance data (heating, cooling, blower): Yes No
Manual D Friction Rate Worksheet: Yes No
Duct distribution system sketch: Yes No

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature 40 °F
Indoor temperature 72 °F
Total heat loss 27275 Btu/h

Summer Design Conditions

Outdoor temperature 100 °F
Indoor temperature 75 °F
Grains difference 21 Δ Gr @ 50 % Rh
Sensible heat gain 52884 Btu/h
Latent heat gain 6540 Btu/h
Total heat gain 59424 Btu/h


Building Construction Information

Building

Orientation (Front door faces) North
North, East, West, South, Northeast, Northwest, Southeast, Southwest
Number of bedrooms 3
Conditioned floor area 2889 Sq Ft
Number of occupants 18

Windows

Eave overhang depth 4 Ft
Internal shade _____
Blinds, drapes, etc
Number of skylights 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type _____ Electric Resistance _____
Furnace, Heat pump, Boiler, etc.

Cooling Equipment Data

Equipment type _____ Standard Air Conditioner _____
Air Conditioner, Heat pump, etc

Blower Data

Heating CFM 2461 CFM
Cooling CFM 2461 CFM

Heating output capacity 60000 Btu/h
Heat pumps - capacity at winter design outdoor conditions

Sensible cooling capacity 60000 Btu/h

Latent cooling capacity _____ Btu/h

Auxiliary heat output capacity _____ Btu/h

Total cooling capacity 60000 Btu/h

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow _____ CFM

Longest supply duct: _____ Ft

Duct Materials Used (circle)

External Static Pressure (ESP) _____ IWC

Longest return duct: _____ Ft

Trunk Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify) _____

Component Pressure Losses (CPL) _____ IWC

Total Effective Length (TEL) _____ Ft

Branch Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify) _____

Available Static Pressure (ASP) _____ IWC

Friction Rate: _____ IWC

ASP = ESP - CPL

Friction Rate = (ASP × 100) ÷ TEL

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's Printed Name John Doe

Date _____

Contractor's Signature John Doe

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.

¹ The AHJ shall have the discretion to accept Required Attachments printed from approved ACCA software vendors, see list on page 2 of instructions.

² If abridged version of Manual J is used for load calculation, then verify residence meets requirements, see Abridged Edition Checklist on page 13 of instructions.



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1.01
8 Mar 10

County, Town, Municipality, Jurisdiction
Header Information

Contractor _____
Mechanical License # _____
Building Plan # _____
Home Address (Street or Lot#, Block, Subdivision) _____

REQUIRED ATTACHMENTS¹ ATTACHED
Manual J1 Form (and supporting worksheets): Yes No
or MJ1AE Form² (and supporting worksheets): Yes No
OEM performance data (heating, cooling, blower): Yes No
Manual D Friction Rate Worksheet: Yes No
Duct distribution system sketch: Yes No

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature _____ °F
Indoor temperature _____ °F
Total heat loss _____ Btu/h

Summer Design Conditions

Outdoor temperature _____ °F
Indoor temperature _____ °F
Grains difference _____ Δ Gr @ _____ % Rh
Sensible heat gain _____ Btu/h
Latent heat gain _____ Btu/h
Total heat gain _____ Btu/h


Building Construction Information

Building

Orientation (Front door faces) _____
North, East, West, South, Northeast, Northwest, Southeast, Southwest
Number of bedrooms _____
Conditioned floor area _____ Sq Ft
Number of occupants _____

Windows

Eave overhang depth _____ Ft
Internal shade _____
Blinds, drapes, etc
Number of skylights _____



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type _____
Furnace, Heat pump, Boiler, etc.
Model _____
Heating output capacity _____ Btu/h
Heat pumps - capacity at winter design outdoor conditions
Auxiliary heat output capacity _____ Btu/h

Cooling Equipment Data

Equipment type _____
Air Conditioner, Heat pump, etc
Model _____
Sensible cooling capacity _____ Btu/h
Latent cooling capacity _____ Btu/h
Total cooling capacity _____ Btu/h

Blower Data

Heating CFM _____ CFM
Cooling CFM _____ CFM

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow _____ CFM Longest supply duct: _____ Ft Duct Materials Used (circle)
External Static Pressure (ESP) _____ IWC Longest return duct: _____ Ft Trunk Duct: Duct board, Flex, Sheet metal,
Component Pressure Losses (CPL) _____ IWC Total Effective Length (TEL) _____ Ft Lined sheet metal, Other (specify)
Available Static Pressure (ASP) _____ IWC Friction Rate: _____ IWC Branch Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify)
ASP = ESP - CPL Friction Rate = (ASP × 100) ÷ TEL

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's Printed Name _____ Date _____
Contractor's Signature _____

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.

¹ The AHJ shall have the discretion to accept Required Attachments printed from approved ACCA software vendors, see list on page 2 of instructions.
² If abridged version of Manual J is used for load calculation, then verify residence meets requirements, see Abridged Edition Checklist on page 13 of instructions.
Form generated by ACCA-approved Manual J Eighth Edition Version 2 Elite Software Rhvac program.



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1.01
8 Mar 10

County, Town, Municipality, Jurisdiction
Header Information

Contractor John Doe
Mechanical License # 12345
Building Plan # _____
Home Address (Street or Lot#, Block, Subdivision) _____

REQUIRED ATTACHMENTS¹ ATTACHED
Manual J1 Form (and supporting worksheets): Yes No
or MJ1AE Form² (and supporting worksheets): Yes No
OEM performance data (heating, cooling, blower): Yes No
Manual D Friction Rate Worksheet: Yes No
Duct distribution system sketch: Yes No

HVAC LOAD CALCULATION (UMC 1106.1)

Design Conditions

Winter Design Conditions

Outdoor temperature 40 °F
Indoor temperature 72 °F
Total heat loss 27275 Btu/h

Summer Design Conditions

Outdoor temperature 100 °F
Indoor temperature 75 °F
Grains difference 21 Δ Gr @ 50 % Rh
Sensible heat gain 52884 Btu/h
Latent heat gain 6540 Btu/h
Total heat gain 59424 Btu/h


Building Construction Information

Building

Orientation (Front door faces) North
North, East, West, South, Northeast, Northwest, Southeast, Southwest
Number of bedrooms 3
Conditioned floor area 2889 Sq Ft
Number of occupants 18

Windows

Eave overhang depth 4 Ft
Internal shade _____
Blinds, drapes, etc
Number of skylights 0



HVAC EQUIPMENT SELECTION

Heating Equipment Data

Equipment type _____ Electric Resistance _____
Furnace, Heat pump, Boiler, etc.

Cooling Equipment Data

Equipment type _____ Standard Air Conditioner _____
Air Conditioner, Heat pump, etc

Blower Data

Heating CFM 2461 CFM
Cooling CFM 2461 CFM

Heating output capacity 60000 Btu/h
Heat pumps - capacity at winter design outdoor conditions

Sensible cooling capacity 60000 Btu/h

Latent cooling capacity _____ Btu/h

Auxiliary heat output capacity _____ Btu/h

Total cooling capacity 60000 Btu/h

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (UMC 601.2)

Design airflow _____ CFM

Longest supply duct: _____ Ft

Duct Materials Used (circle)

External Static Pressure (ESP) _____ IWC

Longest return duct: _____ Ft

Trunk Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify) _____

Component Pressure Losses (CPL) _____ IWC

Total Effective Length (TEL) _____ Ft

Branch Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify) _____

Available Static Pressure (ASP) _____ IWC

Friction Rate: _____ IWC

ASP = ESP - CPL

Friction Rate = (ASP × 100) ÷ TEL

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's Printed Name John Doe

Date _____

Contractor's Signature John Doe

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.

¹ The AHJ shall have the discretion to accept Required Attachments printed from approved ACCA software vendors, see list on page 2 of instructions.

² If abridged version of Manual J is used for load calculation, then verify residence meets requirements, see Abridged Edition Checklist on page 13 of instructions.



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1.01
8 Mar 10

County, Town, Municipality, Jurisdiction
Header Information

Contractor _____
Mechanical License # _____
Building Plan # _____
Home Address (Street or Lot#, Block, Subdivision) _____

REQUIRED ATTACHMENTS¹ ATTACHED
Manual J1 Form (and supporting worksheets): Yes No
or MJ1AE Form² (and supporting worksheets): Yes No
OEM performance data (heating, cooling, blower): Yes No
Manual D Friction Rate Worksheet: Yes No
Duct distribution system sketch: Yes No

HVAC LOAD CALCULATION (UMC 1106.1)

Design Conditions

Winter Design Conditions

Outdoor temperature _____ °F
Indoor temperature _____ °F
Total heat loss _____ Btu/h

Summer Design Conditions

Outdoor temperature _____ °F
Indoor temperature _____ °F
Grains difference _____ Δ Gr @ _____ % Rh
Sensible heat gain _____ Btu/h
Latent heat gain _____ Btu/h
Total heat gain _____ Btu/h


Building Construction Information

Building

Orientation (Front door faces) _____
North, East, West, South, Northeast, Northwest, Southeast, Southwest
Number of bedrooms _____
Conditioned floor area _____ Sq Ft
Number of occupants _____

Windows

Eave overhang depth _____ Ft
Internal shade _____
Blinds, drapes, etc _____
Number of skylights _____



HVAC EQUIPMENT SELECTION

Heating Equipment Data

Equipment type _____
Furnace, Heat pump, Boiler, etc.
Model _____
Heating output capacity _____ Btu/h
Heat pumps - capacity at winter design outdoor conditions
Auxiliary heat output capacity _____ Btu/h

Cooling Equipment Data

Equipment type _____
Air Conditioner, Heat pump, etc
Model _____
Sensible cooling capacity _____ Btu/h
Latent cooling capacity _____ Btu/h
Total cooling capacity _____ Btu/h

Blower Data

Heating CFM _____ CFM
Cooling CFM _____ CFM

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (UMC 601.2)

Design airflow _____ CFM Longest supply duct: _____ Ft Duct Materials Used (circle)
External Static Pressure (ESP) _____ IWC Longest return duct: _____ Ft Trunk Duct: Duct board, Flex, Sheet metal,
Component Pressure Losses (CPL) _____ IWC Total Effective Length (TEL) _____ Ft Lined sheet metal, Other (specify)
Available Static Pressure (ASP) _____ IWC Friction Rate: _____ IWC Branch Duct: Duct board, Flex, Sheet metal,
Lined sheet metal, Other (specify)
ASP = ESP - CPL Friction Rate = (ASP × 100) ÷ TEL

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's Printed Name _____ Date _____
Contractor's Signature _____

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.

¹ The AHJ shall have the discretion to accept Required Attachments printed from approved ACCA software vendors, see list on page 2 of instructions.
² If abridged version of Manual J is used for load calculation, then verify residence meets requirements, see Abridged Edition Checklist on page 13 of instructions.
Form generated by ACCA-approved Manual J Eighth Edition Version 2 Elite Software Rhvac program.



ENERGY STAR Single-Family New Homes

National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

HVAC Designer Responsibilities:

- Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.²
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³
- Provide the completed National HVAC Design Report to the builder or credentialed HVAC contractor and to the Rater.

1. Design Overview

1.1 Designer Name: Engr Rahaman Designer company: _____ Date: October 22, 2025

1.2 Select which party you are providing these design services to: Builder or Credentialed HVAC contractor

1.3 Name of company you are providing these design services to (if different than Item 1.1): _____

1.4 Area that system serves: Whole-house Upper-level Lower-level Other _____

1.5 Is cooling system for a temporary occupant load? ⁴ Yes No

1.6 House plan: 499 Jay Windom Martin Residence Hvac Design Check box to indicate whether the system design is site-specific or part of a group: ²

Site-specific design. Option(s) & elevation(s) modeled: _____

Group design. Group #: _____ out of _____ total groups for this house plan. Configuration modeled: _____

2. Dwelling Unit Mechanical Ventilation System Design ("Vent System") ^{5, 6, 7} & Inlets in Return Duct ⁸

Designer Verified

Airflow:

2.1 Ventilation airflow design rate & run-time meet the requirements of ASHRAE 62.2-2010 or later. ⁹

2.2 Ventilation airflow rate required by 62.2 for a continuous system 74 CFM -

2.3 Design for this system: Vent. airflow rate: 0 CFM Run-time per cycle: _____ minutes Cycle time: _____ minutes -

System Type & Controls:

2.4 Specified system type: Supply Exhaust Balanced -

2.5 Specified control location: _____ (e.g., Master bath, utility room) -

2.6 Specified controls allow the system to operate automatically, without occupant intervention

2.7 Specified controls include a readily-accessible ventilation override and a label has also been specified if its function is not obvious (e.g., a label is required for a toggle wall switch, but not for a switch that's on the ventilation equipment).

2.8 For any outdoor air inlet designed to connect to a ducted return of the HVAC system, specified controls automatically restrict airflow using a motorized damper during ventilation off-cycle and occupant override. ^{8, 10}

Sound: 2.9 The fan of the specified system is rated ≤ 3 sones if intermittent and ≤ 1 sone if continuous, or exempted. ¹¹

Efficiency:

2.10 If Vent System controller operates the HVAC fan, then HVAC fan operation is intermittent and either the fan type in Item 4.7 is ECM / ICM or the controls will reduce the run-time by accounting for HVAC system heating or cooling hours. ¹²

2.11 If bathroom fans are specified as part of the system, then they are ENERGY STAR certified. ¹³

Air Inlet Location: (Complete this section if system has a specified air inlet location; otherwise check "N/A") ¹⁴ N/A

2.12 Inlet pulls ventilation air directly from outdoors and not from attic, crawlspace, garage, or adjacent dwelling unit

2.13 Inlet is ≥ 2 ft. above grade or roof deck; ≥ 10 ft. of stretched-string distance from known contamination sources (e.g., stack, vent, exhaust, vehicles) not exiting the roof, and ≥ 3 ft. from known sources exiting the roof. ¹⁵

3. Room-by-Room Heating & Cooling Loads ¹⁶

3.1 Room-by-room loads calculated using: Unabridged ACCA Manual J v8 2013 ASHRAE Fundamentals Other per AHJ ¹⁷ -

3.2 Indoor design temperatures used in loads are 70°F for heating and 75°F for cooling

3.3 Outdoor design temperatures used in loads: (See Footnote 18 and www.energystar.gov/hvacdesigntemps) ¹⁸ -
County & State, or US Territory, selected: _____ Cooling season: 100 °F Heating season: 40 °F

3.4 Number of occupants used in loads: ¹⁹ 18 -

3.5 Conditioned floor area used in loads: ²⁰ 2889 Sq. Ft. -

3.6 Window area used in loads: ²¹ 849 Sq. Ft. -

3.7 Predominant window SHGC used in loads: ²² 0.62 -

3.8 Infiltration rate used in loads: ²³ Summer: 0 Winter: 0 -

3.9 Mechanical ventilation rate used in loads: 0 CFM -

Loads At Design Conditions (kBtuh)

| | N | NE | E | SE | S | SW | W | NW | | |
|---------|--|------|------|------|------|------|------|-------|-------|---|
| Cooling | 3.10 Sensible heat gain (By orientation ²⁴) | 52.9 | 78.1 | 87.5 | 67.5 | 56.8 | 87.6 | 113.4 | 96.3 | - |
| | 3.11 Latent heat gain (Not by orientation) | 6.5 | | | | | | | | - |
| | 3.12 Total heat gain (By orientation ²⁴) | 59.4 | 84.6 | 94 | 74.1 | 63.3 | 94.1 | 119.9 | 102.9 | - |
| | 3.13 Maximum - minimum total heat gain (Item 3.12) across orientations = <u>60.5</u> kBtuh Variation is ≤ 6 kBtuh ^{24, 25} | | | | | | | | | |
| Heating | 3.14 Total heat loss (Not by orientation) | 27.3 | | | | | | | | - |



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

| 4. Heating & Cooling Equipment Selection ¹⁶ | | | | | | Designer Verified |
|---|----------------------|---|---|---|----------------------|-------------------------------------|
| 4.1 Equipment selected per ACCA Manual S (see Footnote 25 & 26) ^{26, 27} | | | | | | <input checked="" type="checkbox"/> |
| Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A") | | | | | | <input type="checkbox"/> N/A |
| 4.2 Equipment type: <input type="checkbox"/> Cooling-only air conditioner or <input type="checkbox"/> Cooling & heating heat pump | | | | | | - |
| 4.3 Condenser manufacturer & model: GOODMAN, Heat Pump:CHPE4860D4+.outdoor unit:GSX160611F | | | | | | - |
| 4.4 Evaporator / fan coil manufacturer & model: | | | | | | - |
| 4.5 AHRI reference #: ²⁸ | | | | | | - |
| 4.6 Rated cooling efficiency: ²⁹ 16 SEER / Rated heating efficiency: | | | | | | - |
| 4.7 Evaporator fan type: <input type="checkbox"/> PSC <input type="checkbox"/> ECM / ICM <input type="checkbox"/> Other: | | | | | | - |
| 4.8 Compressor type: <input type="checkbox"/> Single-speed <input type="checkbox"/> Two-speed <input type="checkbox"/> Variable-speed | | | | | | - |
| 4.9 Latent capacity at design conditions, from OEM expanded performance data: ³¹ 0 kBtuh | | | | | | - |
| 4.10 Sensible capacity at design conditions, from OEM expanded performance data: ³¹ 60 kBtuh | | | | | | - |
| 4.11 Total capacity at design conditions, from OEM expanded performance data: ³¹ 60 kBtuh | | | | | | - |
| 4.12 Air-source heat pump capacity: At 17°F: 0 kBtuh At 47°F: 0 kBtuh <input type="checkbox"/> N/A | | | | | | - |
| 4.13 Cooling sizing % = Total capacity (Item 4.11) divided by maximum total heat gain (Item 3.12): 50 % | | | | | | - |
| 4.14 Complete this item if Condition B Climate will be used to select sizing limit in Item 4.15. Otherwise, check "N/A": ³² <input type="checkbox"/> N/A | | | | | | - |
| 4.14.1 Load sensible heat ratio = Max sensible heat gain (Item 3.10) / Max. total heat gain (Item 3.12) = 89 % | | | | | | - |
| 4.14.2 HDD / CDD ratio (Visit energystar.gov/hvacdesigntemps to determine this value for the design location) = | | | | | | - |
| 4.15 Check box of applicable cooling sizing limit from chart below: ^{26, 27} | | | | | | - |
| Equipment Type (Per Item 4.2) & Climate Condition (Per Item 4.14) | | Compressor Type (Per Item 4.8) | | | | |
| | | Single-Speed | Two-Speed | Variable-Speed | | |
| For Cooling-Only Equipment or For Cooling Mode of Heat Pump in Condition A Climate | | <input type="checkbox"/> Recommended: 90 - 115% Allowed: 90 - 130% | <input type="checkbox"/> Recommended: 90 - 120% Allowed: 90 - 140% | <input type="checkbox"/> Recommended: 90 - 130% Allowed: 90 - 160% | | |
| For Cooling Mode of Heat Pump in Condition B Climate | | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | | |
| 4.16 Cooling sizing % (4.13) is within cooling sizing limit (4.15) | | | | | | <input type="checkbox"/> |
| Furnace (Complete if furnace will be installed; otherwise check "N/A") | | | | | | <input type="checkbox"/> N/A |
| 4.17 Furnace manufacturer & model: GOODMAN, Heat Pump Indoor:CHPE4860D4+.outdoor unit:GSZH506010A | | | | | | - |
| 4.18 Rated heating efficiency: 0 AFUE | | | | | | - |
| 4.19 Total capacity: ³³ 60 kBtuh | | | | | | - |
| 4.20 Heating sizing % = Total capacity (Item 4.19) divided by total heat loss (Item 3.14): 220 % | | | | | | - |
| 4.21 Check box of applicable heating sizing limit from chart below: | | | | | | - |
| When Used for Heating Only | | | When Paired With Cooling | | | |
| <input type="checkbox"/> 100 - 140% | | | <input checked="" type="checkbox"/> Recommended: 100 - 140% Allowed: 100 - 400% | | | |
| 4.22 Heating sizing % (4.20) is within heating sizing limit (4.21) | | | | | | <input type="checkbox"/> |
| 5. Duct Design (Complete if heating or cooling equipment will be installed with ducts; otherwise check "N/A") ¹⁶ | | | | | | <input type="checkbox"/> N/A |
| 5.1 Duct system designed for the equipment selected in Section 4, per ACCA Manual D | | | | | | <input type="checkbox"/> |
| 5.2 Design HVAC fan airflow: ³⁴ Cooling mode 2461 CFM Heating mode 363 CFM | | | | | | - |
| 5.3 Design HVAC fan speed setting (e.g., low, medium, high): ³⁵ Cooling mode Heating mode | | | | | | - |
| 5.4 Design total external static pressure (corresponding to the mode with the higher airflow in Item 5.2): ³⁶ 0 IWC | | | | | | - |
| 5.5 Room-by-room design airflows documented below (which must sum to the mode with the higher airflow in Item 5.2) ^{37, 38} | | | | | | - |
| Room Name | Design Airflow (CFM) | Room Name | Design Airflow (CFM) | Room Name | Design Airflow (CFM) | |
| 1 Main Floor Entrance | 241 | 12 Second Floor Master Bath | 54 | 23 | | |
| 2 Main Floor Office | 307 | 13 Second Floor Bedroom 2 | 153 | 24 | | |
| 3 Main Floor Kitchen | 221 | 14 Second Floor Bathroom | 47 | 25 | | |
| 4 Main Floor Dinning | 287 | 15 Second Floor Bedroom-3 | 170 | 26 | | |
| 5 Main Floor Living | 342 | 16 Second Floor Hallway | 85 | 27 | | |
| 6 Main Floor Pantry | 38 | 17 | | 28 | | |
| 7 Main Floor Powder | 54 | 18 | | 29 | | |
| 8 Main Floor Rear Entrance | 65 | 19 | | 30 | | |
| 9 Second Floor Laundry | 91 | 20 | | 31 | | |
| 10 Second Floor Dressing Room | 92 | 21 | | 32 | | |
| 11 Second Floor Masterbed | 213 | 22 | | Total for all rooms | | 2461 |



ENERGY STAR Single-Family New Homes

National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

HVAC Designer Responsibilities:

- Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.²
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³
- Provide the completed National HVAC Design Report to the builder or credentialed HVAC contractor and to the Rater.

1. Design Overview

1.1 Designer Name: _____ Designer company: _____ Date: _____

1.2 Select which party you are providing these design services to: Builder or Credentialed HVAC contractor

1.3 Name of company you are providing these design services to (if different than Item 1.1): _____

1.4 Area that system serves: Whole-house Upper-level Lower-level Other _____

1.5 Is cooling system for a temporary occupant load?⁴ Yes No

1.6 House plan: _____ Check box to indicate whether the system design is site-specific or part of a group:²

Site-specific design. Option(s) & elevation(s) modeled: _____

Group design. Group #: _____ out of _____ total groups for this house plan. Configuration modeled: _____

2. Dwelling Unit Mechanical Ventilation System Design ("Vent System")^{5, 6, 7} & Inlets in Return Duct⁸

Designer Verified

Airflow:

2.1 Ventilation airflow design rate & run-time meet the requirements of ASHRAE 62.2-2010 or later.⁹

2.2 Ventilation airflow rate required by 62.2 for a continuous system _____ CFM -

2.3 Design for this system: Vent. airflow rate: _____ CFM Run-time per cycle: _____ minutes Cycle time: _____ minutes -

System Type & Controls:

2.4 Specified system type: Supply Exhaust Balanced -

2.5 Specified control location: _____ (e.g., Master bath, utility room) -

2.6 Specified controls allow the system to operate automatically, without occupant intervention

2.7 Specified controls include a readily-accessible ventilation override and a label has also been specified if its function is not obvious (e.g., a label is required for a toggle wall switch, but not for a switch that's on the ventilation equipment).

2.8 For any outdoor air inlet designed to connect to a ducted return of the HVAC system, specified controls automatically restrict airflow using a motorized damper during ventilation off-cycle and occupant override.^{8, 10}

Sound: 2.9 The fan of the specified system is rated ≤ 3 sones if intermittent and ≤ 1 sone if continuous, or exempted.¹¹

Efficiency:

2.10 If Vent System controller operates the HVAC fan, then HVAC fan operation is intermittent and either the fan type in Item 4.7 is ECM / ICM or the controls will reduce the run-time by accounting for HVAC system heating or cooling hours.¹²

2.11 If bathroom fans are specified as part of the system, then they are ENERGY STAR certified.¹³

Air Inlet Location: (Complete this section if system has a specified air inlet location; otherwise check "N/A")¹⁴ N/A

2.12 Inlet pulls ventilation air directly from outdoors and not from attic, crawlspace, garage, or adjacent dwelling unit

2.13 Inlet is ≥ 2 ft. above grade or roof deck; ≥ 10 ft. of stretched-string distance from known contamination sources (e.g., stack, vent, exhaust, vehicles) not exiting the roof, and ≥ 3 ft. from known sources exiting the roof.¹⁵

3. Room-by-Room Heating & Cooling Loads¹⁶

3.1 Room-by-room loads calculated using: Unabridged ACCA Manual J v8 2013 ASHRAE Fundamentals Other per AHJ¹⁷ -

3.2 Indoor design temperatures used in loads are 70°F for heating and 75°F for cooling

3.3 Outdoor design temperatures used in loads: (See Footnote 18 and www.energystar.gov/hvacdesigntemps)¹⁸ -
County & State, or US Territory, selected: _____ Cooling season: _____°F Heating season: _____°F

3.4 Number of occupants used in loads:¹⁹ _____ -

3.5 Conditioned floor area used in loads:²⁰ _____ Sq. Ft. -

3.6 Window area used in loads:²¹ _____ Sq. Ft. -

3.7 Predominant window SHGC used in loads:²² _____ -

3.8 Infiltration rate used in loads:²³ Summer: _____ Winter: _____ -

3.9 Mechanical ventilation rate used in loads: _____ CFM -

Loads At Design Conditions (kBtuh)

| | N | NE | E | SE | S | SW | W | NW | - |
|--|---|----|---|----|---|----|---|----|---|
|--|---|----|---|----|---|----|---|----|---|

| | | | | | | | | | |
|---------|--|---|--|--|--|--|--|--|--------------------------|
| Cooling | 3.10 Sensible heat gain (By orientation) ²⁴ | | | | | | | | - |
| | 3.11 Latent heat gain (Not by orientation) | | | | | | | | - |
| | 3.12 Total heat gain (By orientation) ²⁴ | | | | | | | | - |
| | 3.13 Maximum - minimum total heat gain (Item 3.12) across orientations = _____ kBtuh | Variation is ≤ 6 kBtuh ^{24, 25} | | | | | | | <input type="checkbox"/> |

| | | | | | | | | | |
|---------|---|--|--|--|--|--|--|--|---|
| Heating | 3.14 Total heat loss (Not by orientation) | | | | | | | | - |
|---------|---|--|--|--|--|--|--|--|---|



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

| 4. Heating & Cooling Equipment Selection ¹⁶ | | | | | | Designer Verified |
|---|----------------------|---|---|---|----------------------|------------------------------|
| 4.1 Equipment selected per ACCA Manual S (see Footnote 25 & 26) ^{26, 27} | | | | | | <input type="checkbox"/> |
| Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A") | | | | | | <input type="checkbox"/> N/A |
| 4.2 Equipment type: <input type="checkbox"/> Cooling-only air conditioner or <input type="checkbox"/> Cooling & heating heat pump | | | | | | - |
| 4.3 Condenser manufacturer & model: _____ | | | | | | - |
| 4.4 Evaporator / fan coil manufacturer & model: _____ | | | | | | - |
| 4.5 AHRI reference #: ²⁸ _____ | | | | | | - |
| 4.6 Rated cooling efficiency: ²⁹ _____ / _____ Rated heating efficiency: _____ | | | | | | - |
| 4.7 Evaporator fan type: <input type="checkbox"/> PSC <input type="checkbox"/> ECM / ICM <input type="checkbox"/> Other: _____ | | | | | | - |
| 4.8 Compressor type: <input type="checkbox"/> Single-speed <input type="checkbox"/> Two-speed <input type="checkbox"/> Variable-speed | | | | | | - |
| 4.9 Latent capacity at design conditions, from OEM expanded performance data: ³¹ _____ kBtuh | | | | | | - |
| 4.10 Sensible capacity at design conditions, from OEM expanded performance data: ³¹ _____ kBtuh | | | | | | - |
| 4.11 Total capacity at design conditions, from OEM expanded performance data: ³¹ _____ kBtuh | | | | | | - |
| 4.12 Air-source heat pump capacity: At 17°F: _____ kBtuh At 47°F: _____ kBtuh <input type="checkbox"/> N/A | | | | | | - |
| 4.13 Cooling sizing % = Total capacity (Item 4.11) divided by maximum total heat gain (Item 3.12): _____ % | | | | | | - |
| 4.14 Complete this item if Condition B Climate will be used to select sizing limit in Item 4.15. Otherwise, check "N/A": ³² <input type="checkbox"/> N/A | | | | | | - |
| 4.14.1 Load sensible heat ratio = Max sensible heat gain (Item 3.10) / Max. total heat gain (Item 3.12) = _____ % | | | | | | - |
| 4.14.2 HDD / CDD ratio (Visit energystar.gov/hvacdesigntemps to determine this value for the design location) = _____ | | | | | | - |
| 4.15 Check box of applicable cooling sizing limit from chart below: ^{26, 27} | | | | | | - |
| Equipment Type (Per Item 4.2) & Climate Condition (Per Item 4.14) | | Compressor Type (Per Item 4.8) | | | | |
| | | Single-Speed | Two-Speed | Variable-Speed | | |
| For Cooling-Only Equipment or For Cooling Mode of Heat Pump in Condition A Climate | | <input type="checkbox"/> Recommended: 90 - 115% Allowed: 90 - 130% | <input type="checkbox"/> Recommended: 90 - 120% Allowed: 90 - 140% | <input type="checkbox"/> Recommended: 90 - 130% Allowed: 90 - 160% | | |
| For Cooling Mode of Heat Pump in Condition B Climate | | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | <input type="checkbox"/> 90% - 100%, plus 15 kBtuh | | |
| 4.16 Cooling sizing % (4.13) is within cooling sizing limit (4.15) | | | | | | <input type="checkbox"/> |
| Furnace (Complete if furnace will be installed; otherwise check "N/A") | | | | | | <input type="checkbox"/> N/A |
| 4.17 Furnace manufacturer & model: _____ | | | | | | - |
| 4.18 Rated heating efficiency: _____ AFUE | | | | | | - |
| 4.19 Total capacity: ³³ _____ kBtuh | | | | | | - |
| 4.20 Heating sizing % = Total capacity (Item 4.19) divided by total heat loss (Item 3.14): _____ % | | | | | | - |
| 4.21 Check box of applicable heating sizing limit from chart below: | | | | | | - |
| When Used for Heating Only | | | When Paired With Cooling | | | |
| <input type="checkbox"/> 100 - 140% | | | <input type="checkbox"/> Recommended: 100 - 140% Allowed: 100 - 400% | | | |
| 4.22 Heating sizing % (4.20) is within heating sizing limit (4.21) | | | | | | <input type="checkbox"/> |
| 5. Duct Design (Complete if heating or cooling equipment will be installed with ducts; otherwise check "N/A") ¹⁶ | | | | | | <input type="checkbox"/> N/A |
| 5.1 Duct system designed for the equipment selected in Section 4, per ACCA Manual D | | | | | | <input type="checkbox"/> |
| 5.2 Design HVAC fan airflow: ³⁴ Cooling mode _____ CFM Heating mode _____ CFM | | | | | | - |
| 5.3 Design HVAC fan speed setting (e.g., low, medium, high): ³⁵ Cooling mode _____ Heating mode _____ | | | | | | - |
| 5.4 Design total external static pressure (corresponding to the mode with the higher airflow in Item 5.2): ³⁶ _____ IWC | | | | | | - |
| 5.5 Room-by-room design airflows documented below (which must sum to the mode with the higher airflow in Item 5.2) ^{37, 38} | | | | | | - |
| Room Name | Design Airflow (CFM) | Room Name | Design Airflow (CFM) | Room Name | Design Airflow (CFM) | |
| 1 | | 12 | | 23 | | |
| 2 | | 13 | | 24 | | |
| 3 | | 14 | | 25 | | |
| 4 | | 15 | | 26 | | |
| 5 | | 16 | | 27 | | |
| 6 | | 17 | | 28 | | |
| 7 | | 18 | | 29 | | |
| 8 | | 19 | | 30 | | |
| 9 | | 20 | | 31 | | |
| 10 | | 21 | | 32 | | |
| 11 | | 22 | | Total for all rooms | | |